

**TOWN OF LOS ALTOS HILLS**

26379 Fremont Road  
Los Altos Hills, CA 94022  
Phone: (650) 941-7222  
Fax: (650) 941-3160  
[www.losaltoshills.ca.gov](http://www.losaltoshills.ca.gov)



# Plumbing Fixtures Certificate of Compliance



As of 1 January 2014, Senate Bill 407 requires non-compliant plumbing fixtures to be replaced with water conserving plumbing fixtures when additions, alterations, and improvements are proposed for the building.

**This law applies to all structures built on or before 1 January 1994.**

Plumbing requirements for all new buildings or remodels that involve plumbing fixtures are required to have the flow rates listed below:

Type of Fixture	Quantity	Non-Compliant Plumbing Fixture per Civil Code Sec 1101.3(c)	Required Water-Conserving Plumbing Fixture maximum flow-rates*
Water Closet (toilet)		≥ 1.6 gallons/flush	1.28 gallons/flush
Urinals		> 1 gallon/flush	0.5 gallons/flush
Faucet - Bathroom		> 2.2 gallons/minute	1.5 gallons/minute at 60 psi
Faucet – Kitchen		> 2.2 gallons/minute	1.8 gallons/minute at 60psi
Single Head Shower		> 2.5 gallons/minute	2.0 gallons/minute at 80 psi
Multiple Shower Heads Serving One Shower		> 2.5 gallons/minute	Flow rate of all shower heads combined = 2.0 gallons/minute at 80 psi, controlled by a single valve; or shower shall be designed to allow only one shower head or outlet to be in operation at a time.

*\*The flow rate requirements are per the 2019 California Plumbing Code section 403.0 & 2019 California Green Building Standards Code section 4.303.*

**To self-certify, complete this form and turn it in prior to final inspection:**

I hereby certify that I have replaced or tested, or have had an individual under my direction replace or test all plumbing fixtures covered by Civil Code Section 1101.3(c) for the address and permit listed below:

\_\_\_\_\_  
Address

\_\_\_\_\_  
Permit #

\_\_\_\_\_  
Property Owner’s or Contractor’s Name (PRINT)

\_\_\_\_\_  
Property Owner’s or Contractor’s (SIGNATURE)

\_\_\_\_\_  
Date